

**“ADDENDUM TO SPECIFICATIONS”  
ADDITION TO ORIGINAL BID 2023-15A**

**For the purpose of  
Purchase of New or Used Firetruck with upfit  
DEER CREEK FIRE DEPT**

Original bid specifications did not include the following upfit: Please add pricing for the below described pump to the bid packet submitted or in a separate envelope with revision marked **Bid 2023-15A** if your sealed bid has already been submitted to the Grant County Clerk’s Office.

**A pump capable of meeting the NFPA 1906 performance rating of 50 GPM @ 150 PSI and 150 GPM @ 100 PSI. Pump performance from 5-foot draft at sea level shall be 90 GPM @ 150 PSI, 170 GPM @ 100 PSI and 250 GPM @ 30 PSI.**

(BIDDING VENDOR: Please provide necessary information below or on an additional page of specifications per your manufacturing abilities)


---


---


---

Approved this 18<sup>th</sup> day of December 2023

**BOARD OF COUNTY COMMISSIONERS  
GRANT COUNTY, OKLAHOMA**

  
\_\_\_\_\_  
Steve Stinson, Chairman

  
\_\_\_\_\_  
Craig A. Fredrick, Vice-Chairman

  
\_\_\_\_\_  
Max L. Hess, Member

  
\_\_\_\_\_  
Cindy Pratt, County Clerk

Attest 